

PowerChute Network Shutdown Shutdown Behavior

04/26/2006 Rev3

Notes:

See **PCNS Maximum Shutdown Time Negotiation** for how the Maximum Shutdown Time is determined.

See **PCNS Low Battery Shutdown Behavior** when the UPS goes into a Low Battery condition.

A Graceful Shutdown initiated from the Management Card will signal Graceful Shutdown for Maximum Shutdown Time + 2 Minutes before issuing the requested turn off, sleep, or reboot action to the UPS.

A Graceful Shutdown initiated from a Management Accessory (Interface Expander, UPS Remote Display, Out-Of-Band Management Card, etc) only signals Graceful Shutdown for Low Battery Duration before issuing the requested turn-off, sleep, or reboot action to the UPS

After the UPS turns off, it will automatically turn on when the input power returns.

